



UTHV.S24081 Heat-actuated Devices for Special Application

[Page Bottom](#)

Heat-actuated Devices for Special Application

[See General Information for Heat-actuated Devices for Special Application](#)

PATOL LTD

S24081

Archway House
A4 Bath Road
Padworth, NR Reading RG7 5HR UNITED KINGDOM

Fixed temperature line type heat detectors for indoor/outdoor use, Model(s) 700-070+, 700-090*

* - Intended to be connected to a UL Listed control unit. Temperature ratings are: 90 C (194 F) maximum - 80 C (176 F) minimum alarm temperature.

+ - Intended to be connected to a UL Listed control unit. Temperature ratings are: 70 C (158 F) maximum - 60 C (140 F) minimum alarm temperature.

[Last Updated](#) on 2017-11-17

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".