



UTHV.S24081
Heat-actuated Devices for Special Application

[Page Bottom](#)

Heat-actuated Devices for Special Application

[See General Information for Heat-actuated Devices for Special Application](#)

PATOL LTD
RECTORY RD
PADWORTH COMMON, BERKSHIRE RG7 4JD UNITED KINGDOM

S24081

fixed temperature line type heat detector cable for indoor/outdoor use, Models 700-090 and 700-070. Intended to be connected to a UL Listed control unit. Model 700-090 temperature ratings are: 90° C (194° F) maximum - 80° C (176° F) minimum alarm temperature. Model 700-070 temperature ratings are: 70° C (158° F) maximum - 60° C (140° F) minimum alarm temperature.

[Last Updated](#) on 2006-03-21

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2008 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

