



- NOTES :-
- A) Address Loop Interface Units (ALIU) provided *free issue* by Client
 - B) ALIU installed in enclosure via plate by Patol Limited
 - C) Internal wiring conducted by Patol prior to installation
 - D) Alternative internal wiring configuration available to achieve "pre-alarm" notification to Main Fire Panel . Employs both A1 & A2 trips / contacts.

Patol Limited
 Rectory Road, Padworth Common, Berkshire. U.K. Tel: 0118 9701701

1	Original	03/10/01
Iss.	Change	Date

Patol Limited		
LDM-519-SEN-N		
With Integral Address Loop Interface		
General Arrangement Drawing		
Issue:- 1	Date:- 03/10/01	Drawing Ref. 11008

CAD Ref: 11008_01.wpg